

Franklin Square Water District
PWS ID No. NY2902822
1,4-dioxane and PFOS/PFOA Water Quality Summary



Status as of: January 1, 2021 through March 31, 2021
Prepared By: H2M architects+engineers

Location	Date Sampled	1,4-dioxane (ug/L)		PFOA (ng/L)		PFOS (ng/L)		Treatment in Place (Y/N)	Notes and Comments
		Raw Level	Treated Level	Raw Level	Treated Level	Raw Level	Treated Level		
Well No. 1	3/2/2021		0.080	ND	ND	4.4	ND		
Well No. 2	3/2/2021		0.099	ND	ND	ND	ND		
Well No. 3	3/2/2021		0.11	ND	ND	ND	ND		
Well No. 4	3/2/2021	0.75	0.80	1.9	ND	77.0	ND	Y	GAC

Notes: Well No. 5 was inoperable during the first quarter of 2021.

PFOA Perfluorooctanoic Acid
PFOS Perfluorooctanesulfonic Acid
ND Non-detect
MCL Maximum Contaminant Level
NS Not Sampled

Bold results exceed MCL

Water Quality Test Results Attachments to Follow